

BOARD OF TRUSTEES  
Donald E. Eckmann  
President  
Wallace D. Van Buren  
Vice-President  
George Mitchel  
Clerk

# Downers Grove Sanitary District

2710 Curtiss Street  
P.O. Box 1412  
Downers Grove, IL 60515-0703  
Phone: 630-969-0664  
Fax: 630-969-0827

STAFF  
Lawrence C. Cox  
General Manager  
Ralph E. Smith, Jr.  
Operations Director  
Sheila K. Henschel  
Administrative Services  
Director  
LEGAL COUNSEL  
Michael C. Wiedel

*Providing a Better Environment for South Central  
DuPage County*

January 16, 1998  
Larry McDaniel  
Plant Superintendent  
Tricon Industries, Inc.  
2325 Wisconsin  
Downers Grove, Illinois 60515

EPA Region 5 Records Ctr.



264188

Dear Mr. McDaniel:

The District has recently made revisions to its Industrial Pretreatment Program, as required by USEPA. Specifically these changes were a re-evaluation of the District's ordinance limits for toxic pollutants. The old limits had been in place since 1985 and needed to be updated to reflect regulatory and operational changes.

Two copies of this permit revision are enclosed. In summary, arsenic and selenium have been added to the list of pollutants with specific local limits. All the other listed pollutant parameters have limits that were revised downward, except for silver, which remains at 0.57 mg/L.

Please review the limit changes and attach the permit revision to the complete permit. I don't believe these changes will have any impact on your operations or compliance. The new limits are enforcement limits 30 days after this notice, February 16, 1998.

Please feel free to call me if you have any questions.

Sincerely,  
**DOWNERS GROVE SANITARY DISTRICT**

Janet M. Buchner  
Laboratory Services Director

Enclosure

**DOWNERS GROVE SANITARY DISTRICT**

Discharge Permit Number 2

Issuance Date: October 15, 1995

Expiration Date: October 15, 2000

Revision Date: January 15, 1998

Permittee Name: Tricon Industries, Inc.

Permittee Address: 1600 Eisenhower Lane  
Lisle, Illinois 60532

Name of Premise Permitted: Tricon Industries, Inc.  
Electromechanical Division

Location of Permitted Premise: 2325 Wisconsin Avenue  
Downers Grove, Illinois 60515


In accordance with the provisions of Section VI, Term of Permit, this permit is hereby revised to set the wastewater discharge limits to new values that have been approved by the District Board of Trustees. These limits replace the old limits entirely and become compliance limits 30 days from the date of this notice.

The following section is being added to the permit:

Section II(G). The total discharge flow from this facility to the sanitary sewer system shall not exceed the following specific limitations at Outfall 001-C, based on a twenty four (24) hour composite sample:

<u>Pollutant</u>	<u>Limit</u>	<u>Pollutant</u>	<u>Limit</u>
Arsenic, Total	0.52 mg/L	Lead, Total	2.15 mg/L
Cadmium, Total	0.28 mg/L	Mercury, Total	0.033 mg/L
Chromium, Total	14.0 mg/L	Nickel, Total	4.27 mg/L
Chromium, Hexavalent	0.81 mg/L	Selenium, Total	0.43 mg/L
Copper, Total	2.54 mg/L	Silver, Total	0.57 mg/L
Cyanide, Total	1.34 mg/L	Zinc, Total	2.61 mg/L

DOWNERS GROVE SANITARY DISTRICT

  
Lawrence C. Cox, District General Manager

## DOWNERS GROVE SANITARY DISTRICT

Discharge Permit Number 2

Issuance Date: October 15, 1995

Expiration Date: October 15, 2000

Revision Date: January 15, 1998

Permittee Name: Tricon Industries, Inc.

Permittee Address: 1600 Eisenhower Lane  
Lisle, Illinois 60532

Name of Premise Permitted: Tricon Industries, Inc.  
Electromechanical Division

Location of Permitted Premise: 2325 Wisconsin Avenue  
Downers Grove, Illinois 60515


In accordance with the provisions of Section VI, Term of Permit, this permit is hereby revised to set the wastewater discharge limits to new values that have been approved by the District Board of Trustees. These limits replace the old limits entirely and become compliance limits 30 days from the date of this notice.

The following section is being added to the permit:

Section II(G). The total discharge flow from this facility to the sanitary sewer system shall not exceed the following specific limitations at Outfall 001-C, based on a twenty four (24) hour composite sample:

<u>Pollutant</u>	<u>Limit</u>	<u>Pollutant</u>	<u>Limit</u>
Arsenic, Total	0.52 mg/L	Lead, Total	2.15 mg/L
Cadmium, Total	0.28 mg/L	Mercury, Total	0.033 mg/L
Chromium, Total	14.0 mg/L	Nickel, Total	4.27 mg/L
Chromium, Hexavalent	0.81 mg/L	Selenium, Total	0.43 mg/L
Copper, Total	2.54 mg/L	Silver, Total	0.57 mg/L
Cyanide, Total	1.34 mg/L	Zinc, Total	2.61 mg/L

DOWNERS GROVE SANITARY DISTRICT

  
Lawrence C. Cox, District General Manager